



Assessment & Sustainable Replacement Options

155 George Street, Prince George, BC

Presented to: Regional District of Fraser-Fort
George (RDFFG)


Prepared by: McCuaig & Associates
Engineering Ltd.

Date: February 20, 2024




AGENDA

- MAE Introduction
- Building Description
- Existing HVAC Assessment
- Energy & GHG Analysis
- Sustainable Replacement Options
- Recommendations
- Q&A



McCuaig and Associates Engineering



Company Introduction

- Founded: 1992 by Jak McCuaig
- Offices: Vancouver, Victoria, Calgary
- Staff: 40+ engineers, technologists, technicians, and administrative personnel
- Services:
 - ❖ Building asset management
 - ❖ Building science
 - ❖ Mechanical
 - ❖ Electrical
 - ❖ Energy Performance
 - Hazmat
- Clients :
 - ❖ Federal/Provincial/ Municipal governments
 - ❖ School Boards
 - ❖ Housing providers
 - ❖ Large Portfolio Holders

McCuaig & Associates Engineering

Today's Speaker




LEAD CONSULTANTS



Dmitrii Konkov, P. ENG.

Today's Discussion...





Building Description

155 George Street, Prince George, BC

- Location: 155 George St, Prince George, BC. ASHRAE 4A Zone with 4720 HDD
- Year Built: 1999, 3 storeys, 27,934 sq. ft.
- Occupancy: RDEFG administrative offices
- Structure: Wood-framed, triple-glazed windows
- HVAC: Hydronic boilers, air-cooled chiller, 1 large AHU, fan coils






Existing HVAC

Distribution


- 24 4- pipe fan coils
- All replaced in 2021 and in good condition
- Minor design issues when supply air goes to one room but returns from another
- All fan coils are “high temperature” fan coils



Existing HVAC

Heating


- 6 condensing boilers, ~270 MBH each
 - 2 IBC boilers installed in 2021. Good Condition
 - 1 Lochinvar installed in 2021. Good Condition
 - 3 HydroTherm boilers original to the building. Poor condition
- Issues:
 - Operating at non-condensing temps (~180°F).
 - Coupled DHW prevents lower return temps.
 - Three boilers used only for backup in extreme cold.



Existing HVAC

Cooling

- 50-ton Daikin chiller installed in 2016 – Good Condition
- Fluid cooler from 2007 (near end of life) – Acceptable Condition
- Issues:
 - Chiller pipe and HX insulation are damaged (likely birds)
 - Fluid cooler is not properly fastened





Existing HVAC

Ventilation

- Single Custom Maid McQuay AHU
- Issues:
 - Originally installed and reached its end of reliable service life
 - Significantly oversized. The unit is 10,000 cfm, while ASHRAE 62.1 (Ventilation in commercial buildings) only requires 3,000 cfm
 - The Oversizing is the reason of the poor performance of the generally well-maintained building



Existing HVAC



Domestic Hot Water

- One storage tank heater by the boiler plant
- One electric tank heater
- Issues:
 - Both reached the end of reliable service life
 - The storage tank is connected to the boiler plant, preventing it from working in a condensing range and decreasing overall efficiency

Electrical Capacity

- 600 V, 3-phase service
- 750 kVa Transformer and 800 A rated Distribution service
- Peak load is 88.9 kW within the last 3 years
- Building Capacity: 560 kW.
- Available Capacity: 471 kW

ENERGY MODEL



| SCENARIO | BASELINE – UTILITY BILLS | BASELINE - SIMULATED | MAE | CVRMSE |
|-------------------------------|--------------------------|----------------------|-------|--------|
| Gas Consumption (kWh) | 567,305.81 | 567,612.10 | 0.05% | 14% |
| Electricity Consumption (kWh) | 375,800.00 | 365,742.90 | -2.7% | 5% |



SUSTAINABLE REPLACEMENT OPTIONS

0. Baseline

| Scope |
|---------------------------|
| Boiler Replacements EOL |
| AHU Replacement ASAP |
| Chiller replaced at EOL |
| Fan Coils replaced at EOL |

| Parameter | Impact |
|---------------------------------|--------------|
| Energy Use | -0 GJ |
| Greenhouse Gas Emissions | - 0 Ton CO2e |
| Energy Costs | -\$0 |
| Capital Costs | \$810,000.00 |
| Financial Metrics (SPP/IRR/NPV) | N/A |





SUSTAINABLE REPLACEMENT OPTIONS

1. Existing System Optimization

| Scope |
|--------------------------------|
| Boiler Plant Redesign |
| AHU Replacement and downsizing |
| Chiller replaced at EOL |
| Fan Coils |

| Parameter | Impact |
|---------------------------------|-----------------------------|
| Energy Use | -798 GJ |
| Greenhouse Gas Emissions | -41.5 Ton CO ₂ e |
| Energy Costs | -\$12,504.92 |
| Capital Costs | \$952,000.00 |
| Financial Metrics (SPP/IRR/NPV) | 11y/ 7% / \$75,749.99 |





SUSTAINABLE REPLACEMENT OPTIONS

2 Geothermal

| Scope |
|--------------------------------|
| Water to Water Heat Pumps |
| Boreholes and resurfacing |
| AHU Replacement and downsizing |
| Fan Coils |

| Parameter | Impact |
|---------------------------------|--------------------------|
| Energy Use | -1,143 GJ |
| Greenhouse Gas Emissions | -72.88 Ton CO2e |
| Energy Costs | -\$7,750.70 |
| Capital Costs | \$1,117,000.00 |
| Financial Metrics (SPP/IRR/NPV) | 40y/ -3% / -\$172,035.99 |





SUSTAINABLE REPLACEMENT OPTIONS

3 Electrification

| Scope |
|--------------------------------|
| Electric Boiler Plant |
| Chiller at EOL |
| AHU Replacement and downsizing |
| Fan Coils at EOL |

| Parameter | Impact |
|---------------------------------|-------------------|
| Energy Use | -976 GJ |
| Greenhouse Gas Emissions | -102.89 Ton CO2e |
| Energy Costs | \$7,372.89 |
| Capital Costs | \$612,000.00 |
| Financial Metrics (SPP/IRR/NPV) | N/A |





SUSTAINABLE REPLACEMENT OPTIONS

4 District Energy System

| Scope |
|---------------------------------------|
| Heat Exchangers and Connection to DES |
| Chiller at EOL |
| AHU Replacement and downsizing |
| Fan Coils at EOL |

| Parameter | Impact |
|---------------------------------|------------------------------|
| Energy Use | -2,071 GJ |
| Greenhouse Gas Emissions | -92.11 Ton CO ₂ e |
| Energy Costs | \$2,337.54 |
| Capital Costs | \$765,000.00 |
| Financial Metrics (SPP/IRR/NPV) | N/A/ N/A/ 82,221.35 |





SUSTAINABLE REPLACEMENT OPTIONS

5 Solar

| Scope |
|---------------|
| No HVAC Scope |
| PV panels |

| Parameter | Impact |
|---------------------------------|-----------------------------|
| Energy Use | -144 GJ |
| Greenhouse Gas Emissions | -0.62 Ton CO ₂ e |
| Energy Costs | -\$3,685.82 |
| Capital Costs | \$135,000.00 |
| Financial Metrics (SPP/IRR/NPV) | 37y/ -3% / -\$70,818.19 |



Incentives and Rebates

Fortis
BC

\$118,350

Clean
BC

\$184,220

FCM

\$153,000

THANK YOU



PHONE
604-255-0992



EMAIL
info@mccuaig.net



WEB
www.mccuaig.net

